

you have been there in the way of heat?

A. When I first went there I found the institution well supplied with heating apparatus. But in some respects there were matters that required some little change. The heating apparatus was put in to heat a less amount of space than was in the institution when I went there. And additional piping had been attached to the original lines of conveying pipe to such an extent that the conveying pipe was in too small proportion to the amount of heating surface it had to supply.

And it became necessary to increase the size of the conveying pipe up to such point as the steam was distributed ~~it~~ for general use over the building. That was done. And in regard to the boilers which had been in use some 14 years and had done very good service, and as much as could be expected, it became apparent soon after I went there that all of them were overtaxed, and it became necessary to remove and replace 3 out of the 4 in the next. One of them coming to a point very near